Federal Insurance and Mitigation Administration

November 2019

# The 2018 International Existing Building Code®: A Compilation of Wind Resistant Provisions

## **Copyright Notice**

This publication reproduces excerpts from copyrighted 2018 I-CODES® of International Code Council, Inc. (ICC), including the International Building Code® (IBC®), the International Existing Building Code® (IEBC®), and the International Residential Code® (IRC®). All excerpts (and their corresponding I-CODES®) are Copyright © 2018 International Code Council, Inc. All rights reserved. All are reproduced with permission from ICC. <a href="www.iccsafe.org">www.iccsafe.org</a>

No portion of any I-CODE, including those excerpts included herein, may be copied, reproduced, distributed or modified, in any way or form, without the express prior written permission of ICC. Permission requests should be directed to Publications, 4051 Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).

This document contains excerpts of the wind provisions from the 2018 edition of the IEBC.

International Code Council®, ICC®, International Building Code®, IBC®, International Existing Building Code®, IEBC®, International Residential Code®, and IRC® are registered trademarks of International Code Council, Inc.

## **Usage Note**

This document provides the wind resistant provisions of the 2018 International Existing Building Code and is not intended to be a compilation of all the related provisions of the IEBC. Where material that was not specific to wind was removed from a code section, "partial shown" is indicated. Where a "user note" or information that may be useful to the reader is provided, it is provided in blue text. A description of applicable figures to the wind resistant provisions are provided in italicized text, and the figure can be seen in the full publication of the IEBC.

# IEBC® 2018 International Existing Building Code

## EFFECTIVE USE OF THE INTERNATIONAL EXISTING BUILDING CODE

The International Existing Building Code is a model code in the International Code family of codes intended to provide requirements for repair and alternative approaches for alterations and additions to existing buildings. A large number of existing buildings and structures do not comply with the current building code requirements for new construction. Although many of these buildings are potentially salvageable, rehabilitation is often cost-prohibitive because compliance with all the requirements for new construction could require extensive changes that go well beyond the value of the building or the original scope of the alteration. At the same time, it is necessary to regulate construction in existing buildings that undergo additions, alterations, extensive repairs or change of occupancy. Such activity represents an opportunity to ensure that new construction complies with the current building codes and that existing conditions are maintained, at a minimum, to their current level of compliance or are improved as required to meet basic safety levels. To accomplish this objective, and to make the alteration process easier, this code allows for options for controlled departure from full compliance with the International

Codes dealing with new construction, while maintaining basic levels for fire prevention, structural and life safety features of the rehabilitated building.

This code provides three main options for a designer in dealing with alterations of existing buildings. These are laid out in Section 301 of this code:

**OPTION 1:** Work for alteration, change of occupancy or addition of all existing buildings shall be done in accordance with the Prescriptive Compliance Method given in Chapter 4. It should be noted that this method originates from the former Chapter 34 of the International Building Code (2012 and earlier editions).

**OPTION 2:** Work for alteration, change of occupancy or addition of all existing buildings shall be done in accordance with the Work Area Compliance Method given in Chapters 6 through 12.

**OPTION 3**: Work for alteration, change of occupancy or addition of all existing buildings shall be done in accordance with the Performance

Compliance Method given in Chapter 13. It should be noted that this option was also provided in the former Chapter 34 of the International Building Code (2012 and earlier editions).

Under limited circumstances, a building alteration can be made to comply with the laws under which the building was originally built, as long as there has been no substantial structural damage and there will be limited structural alteration.

## **Arrangement and Format of the 2018 IEBC**

Before applying the requirements of the IEBC it is beneficial to understand its arrangement and format. The IEBC, like other codes published by ICC, is arranged and organized to follow logical steps that generally occur during a plan review or inspection.

The IEBC is divided as follows:

Chapters	Subjects
1-2	Administrative Requirements and Definitions
3	Provisions for all Compliance Methods
4	Repairs
5	Prescriptive Compliance Method for Existing Buildings
6-12	Prescriptive Compliance Method for Existing Buildings
13	Performance Compliance Method for Existing Buildings
14	Relocated Buildings

15	Construction Safeguards
16	Referenced Standards
Appendix A	Guidelines for Seismic Retrofit of Existing Buildings
Appendix B	Supplementary Accessibility Requirements for Existing Buildings
Appendix C	Guidelines for Wind Retrofit of Existing Buildings
Resource A	Guidelines on Fire Ratings of Archaic Materials and Assemblies

The following is a chapter-by-chapter synopsis of the scope and intent of the provisions of the International Existing Building Code:

User Note: The chapters shown below are those that are highlighted in this document and provide wind resistant provisions.

Chapter 1 Scope and Administration. This chapter contains provisions for the application, enforcement and administration of subsequent requirements of the code. In addition to establishing the scope of the code, Chapter 1 identifies which buildings and structures come under its purview. [partial shown]

**Chapter 2 Definitions.** All defined terms in the code are provided in Chapter 2. [partial shown]

Chapter 3 Provisions for All Compliance Methods. This chapter explains the three compliance options available in the code. Finally this chapter clarifies that provisions in other I-Codes related to repairs, alterations, additions, relocation and changes in occupancy must also be addressed unless they conflict with the IEBC. In that case, the IEBC takes precedence. [partial shown]

**Chapter 4 Repairs.** Chapter 4 governs the repair of existing buildings. The provisions define conditions under which repairs may be made using materials and methods like those of the original construction or the extent to which repairs must comply with requirements for new buildings. [partial shown]

Chapter 5 Prescriptive Compliance Method. This chapter provides one of the three main options of compliance available in the IEBC for buildings and structures undergoing alteration, addition or change in occupancy.

**Chapter 6 Classification of Work.** This chapter provides an overview of the Work Area Method available as an option for rehabilitation of a building. The chapter defines the different classifications of alterations and provides general requirements for alterations, change of occupancy, additions and historic buildings. Detailed requirements for all of these are given in subsequent Chapters 7 through 12.

Chapter 7 Alterations – Level 1. This chapter provides the technical requirements for those existing buildings that undergo Level 1 alterations as described in Section 503, which includes replacement or covering of existing materials, elements, equipment, or fixtures using new materials for the same purpose. *[partial shown]* 

Chapter 8 Alterations – Level 2. Like Chapter 7, the purpose of this chapter is to provide detailed requirements and provisions to identify the required improvements in the existing building elements, building spaces and building structural system when a building is being altered. [partial shown]

Chapter 9 Alterations – Level 3. This chapter provides the technical requirements for those existing buildings that undergo Level 3 alterations. The purpose of this chapter is to provide detailed requirements and provisions to identify the required improvements in the existing building elements, building spaces and building structural system. This chapter is distinguished from Chapters 7 and 8 by involving alterations that cover 50 percent of the aggregate area of the building. At times and under certain situations, this chapter also intends to improve the safety of certain building features beyond the work area and in other parts of the building where no alteration work might be taking place. [partial shown]

User Note: In certain cases, this can trigger additional remedial measure intended to improve the windstorm resistance of the building.

Chapter 10 Change of Occupancy. The purpose of this chapter is to provide regulations for the circumstances when an existing building is subject to a change in occupancy or a change of occupancy classification. A change of occupancy is not to be confused with a change of occupancy classification. [partial shown]

**Chapter 11 Additions.** Chapter 11 provides the requirements for additions, which correlate to the code requirements for new construction. *[partial shown]* 

Chapter 12 Historic Buildings. This chapter provides some exceptions from code requirements when the building in question has historic value. [partial shown]

**Chapter 13 Performance Compliance Methods**. This chapter allows for existing buildings to be evaluated so as to show that alterations, while not meeting new construction requirements, will improve the current existing situation. [partial shown]

Chapter 14 Relocated or Moved Buildings. Chapter 14 is applicable to any building that is moved or relocated.

Appendix C Guidelines for Wind Retrofit of Existing Buildings. This Appendix is intended to provide guidance for retrofitting existing structures to strengthen their resistance to wind forces. This appendix is similar in scope to Appendix A which addresses seismic retrofits for existing buildings except that the subject matter is related to wind retrofits. These retrofits are voluntary measures that serve to better protect the public and reduce damage from high wind events for existing buildings.

The purpose of the Appendix is to provide prescriptive alternatives for addressing retrofit of buildings in high wind areas. Currently there are two chapters which deal with the retrofit of gable ends and the fastening of roof decks, Appendix Chapters C1 and C2 respectively.

#### **CHAPTER 1 SCOPE AND ADMINISTRATION**

## **SECTION 106 CONSTRUCTION DOCUMENTS**

[A] 106.2.4 Exterior wall envelope. The construction documents shall include manufacturer's installation instructions that provide supporting documentation that the proposed penetration and opening details described in the construction documents maintain the wind and weather resistance of the exterior wall envelope. The supporting

<sup>&</sup>lt;sup>1</sup> The "[A]" indicates that the Administrative Code Development Committee is responsible for this portion of the code.

documentation shall fully describe the exterior wall system that was tested, where applicable, as well as the test procedure used. [partial shown]

#### **CHAPTER 2 DEFINITIONS**

#### **SECTION 201 GENERAL**

- [A] ADDITION. An extension or increase in floor area, number of stories, or height of a building or structure.
- [A] ALTERATION. Any construction or renovation to an existing structure other than a repair or addition.
- [A] REPAIR. The reconstruction, replacement or renewal of any part of an existing building for the purpose of its maintenance or to correct damage.
- **[BS]** <sup>1</sup> **SUBSTANTIAL DAMAGE.** For the purpose of determining compliance with the flood provisions of this code, damage of any origin sustained by a structure whereby the cost of restoring the structure to its before-damaged condition would equal or exceed 50 percent of the market value of the structure before the damage occurred.
- **[BS] SUBSTANTIAL IMPROVEMENT.** For the purpose of determining compliance with the flood provisions of this code, any repair, alteration, addition, or improvement of a building or structure, the cost of which equals or exceeds 50 percent of the market value of the structure, before the improvement or repair is started. If the structure has sustained substantial damage, any repairs are considered substantial improvement regardless of the actual repair work performed. The term does not, however, include either:
  - 1. Any project for improvement of a building required to correct existing health, sanitary, or safety code violations identified by the code official and that is the minimum necessary to ensure safe living conditions; or
  - 2. Any alteration of a historic structure, provided that the alteration will not preclude the structure's continued designation as a historic structure.

## **[BS] SUBSTANTIAL STRUCTURAL DAMAGE.** A condition where any of the following apply:

- 1. The vertical elements of the lateral force resisting system have suffered damage such that the lateral load-carrying capacity of any story in any horizontal direction has been reduced by more than 33 percent from its predamage condition.
- 2. The capacity of any vertical component carrying gravity load, or any group of such components, that has a tributary area more than 30 percent of the total area of the structure's floor(s) and roof(s) has been reduced more than 20 percent from its predamage condition and the remaining capacity of such affected elements, with respect to all dead and live loads, is less than 75 percent of that required by the International Building Code for new buildings of similar structure, purpose, and location.
- 3. The capacity of any structural component carrying snow load, or any group of such components, that supports more than 30 percent of the roof area of similar construction has been reduced more than 20 percent from its predamage condition, and the remaining capacity with respect to dead, live and snow loads is less than 75 percent of that required by the International Building Code for new buildings of similar structure, purpose and location.

<sup>&</sup>lt;sup>1</sup> The "[BS]" indicates that the Structural Code Development Committee is responsible for this portion of the code.

#### **CHAPTER 3 PROVISIONS FOR ALL COMPLIANCE METHODS**

#### **SECTION 301 ADMINISTRATION**

- **301.1 General.** The *repair*, *alteration*, *change of occupancy*, *addition* or relocation of all *existing buildings* shall comply with Section 301.2, 301.3, or 301.4.
- **301.2 Repairs.** Repairs shall comply with the requirements of Chapter 4.
- **301.3 Alteration, addition or change of occupancy.** The *alteration, addition* or *change of occupancy* of all *existing buildings* shall comply with one of the methods listed in Section 301.3.1, 301.3.2 or 301.3.3 as selected by the applicant. Sections 301.3.1 through 301.3.3 shall not be applied in combination with each other.

**Exception:** Subject to the approval of the *code official*, *alterations* complying with the laws in existence at the time the building or the affected portion of the building was built shall be considered in compliance with the provisions of this code. New structural members added as part of the *alteration* shall comply with the *International Building Code*. This exception shall not apply to alterations that constitute substantial improvement in *flood hazard areas*, which shall comply with Section 503.2, 701.3 or 1301.3.3. This exception shall not apply to the structural provisions of Chapter 5 or to the structural provisions of Sections 706, 806 and 906.

- **301.3.1 Prescriptive compliance method.** *Alterations*, *additions* and *changes of occupancy* complying with Chapter 5 of this code in buildings complying with the *International Fire Code* shall be considered in compliance with the provisions of this code.
- **301.3.2** Work area compliance method. *Alterations*, *additions* and changes of occupancy complying with the applicable requirements of Chapters 6 through 12 of this code shall be considered in compliance with the provisions of this code.
- **301.3.3 Performance compliance method.** *Alterations*, *additions* and changes of occupancy complying with Chapter 13 of this code shall be considered in compliance with the provisions of this code.

## **SECTION 302 GENERAL PROVISIONS**

- **302.4 Existing materials.** Materials already in use in a building in compliance with requirements or approvals in effect at the time of their erection or installation shall be permitted to remain in use unless determined by the building official to be unsafe.
- **302.5** New and replacement materials. Except as otherwise required or permitted by this code, materials permitted by the applicable code for new construction shall be used. Like materials shall be permitted for *repairs* and *alterations*, provided that unsafe conditions are not created. Hazardous materials shall not be used where the code for new construction would not permit their use in buildings of similar occupancy, purpose and location.
  - [BS] 302.5.1 New structural members and connections. New structural members and connections shall comply with the detailing provisions of the *International Building Code* for new buildings of similar structure, purpose and location.

**Exception**: Where alternative design criteria are specifically permitted.

#### **CHAPTER 4 REPAIRS**

#### **SECTION 401 GENERAL**

**401.2 Compliance.** The work shall not make the building less complying than it was before the *repair* was undertaken.

#### SECTION 405 STRUCTURAL

- [BS] 405.1 General. Structural repairs shall be in compliance with this section and Section 401.2.
- [BS] 405.2 Repairs to damaged buildings. *Repairs* to damaged buildings shall comply with this section.
  - **[BS] 405.2.1 Repairs for less than substantial structural damage.** Unless otherwise required by this section, for damage less than *substantial structural damage*, the damaged elements shall be permitted to be restored to their predamage condition.

[BS] 405.2.3 Substantial structural damage to vertical elements of the lateral force resisting system. A building that has sustained substantial structural damage to the vertical elements of its lateral force-resisting system shall be evaluated and repaired in accordance with Section 405.2.3.1, and either repaired in accordance with Section 405.2.3.2 or repaired and retrofitted in accordance with Section 405.2.3.3, depending on the results of the evaluation.

## **Exceptions:**

- 1. Buildings assigned to Seismic Design Category A, B or C whose substantial structural damage was not caused by earthquake need not be evaluated or retrofitted for load combinations that include earthquake effects.
- 2. One- and two-family dwellings need not be evaluated or retrofitted for load combinations that include earthquake effects.
- [BS] **405.2.3.1 Evaluation.** The building shall be evaluated by a registered design professional, and the evaluation findings shall be submitted to the code official. The evaluation shall establish whether the damaged building, if repaired to its pre-damage state, would comply with the provisions of the International Building Code for for load combinations that include wind or earthquake effects, except that the seismic forces shall be the reduced seismic forces.
- **[BS] 405.2.3.2 Extent of repair for compliant buildings.** If the evaluation establishes that the building in its predamage condition complies with the provisions of Section 405.2.3.1, then the damaged elements shall be permitted to be restored to their predamage condition.
- [BS] 405.2.3.3 Extent of repair for noncompliant buildings. If the evaluation does not establish that the building in its predamage condition complies with the provisions of Section 405.2.3.1, then the building shall be retrofitted to comply with the provisions of this section. The wind loads for the repair and retrofit shall be those required by the building code in effect at the time of original construction, unless the damage was caused by wind, in which case the wind loads shall be in accordance with the International Building Code. [partial shown]
- [BS] 405.2.4.1 Lateral force-resisting elements. Regardless of the level of damage to vertical elements of the lateral force-resisting system, if substantial structural damage to gravity load-carrying components was caused

primarily by wind or seismic effects, then the building shall be evaluated in accordance with Section 405.2.3.1 and, if noncompliant, retrofitted in accordance with Section 405.2.3.3.

## **Exceptions:**

- 1. Buildings assigned to Seismic Design Category A, B, or C whose substantial structural damage was not caused by earthquake need not be evaluated or retrofitted for load combinations that include earthquake effects.
- 2. One- and two-family dwellings need not be evaluated or retrofitted for load combinations that include earthquake effects.

#### CHAPTER 5 PRESCRIPTIVE COMPLIANCE METHOD

## **SECTION 502 ADDITIONS**

**502.1 General.** Additions to any building or structure shall comply with the requirements of the International Building Code for new construction. Alterations to the existing building or structure shall be made to ensure that the existing building or structure together with the addition are not less complying with the provisions of the International Building Code than the existing building or structure was prior to the addition. [partial shown]

[BS] 502.4 Existing structural elements carrying gravity load. Any existing element that will form part of the lateral load path for any part of the *addition* shall be considered to be an existing lateral load-carrying structural element subject to the requirements of Section 502.5. [partial shown]

**Exception:** Buildings of Group R occupancy with not more than five dwelling or sleeping units used solely for residential purposes where the *existing building* and the *addition* together comply with the conventional light-frame construction methods of the *International Building Code* or the provisions of the *International Residential Code*.

[BS] 502.5 Existing structural elements carrying lateral load. Where the *addition* is structurally independent of the *existing structure*, existing lateral load-carrying structural elements shall be permitted to remain unaltered. Where the *addition* is not structurally independent of the *existing structure*, the *existing structure* and its *addition* acting together as a single structure shall be shown to meet the requirements of Sections 1609 and 1613 of the *International Building Code* using full seismic forces.

User Note: Section 1609 of the IBC provides design wind loads.

## **Exceptions:**

- 1. Any existing lateral load-carrying structural element whose demand-capacity ratio with the *addition* considered is not more than 10 percent greater than its demand-capacity ratio with the *addition* ignored shall be permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the demand shall consider applicable load combinations with design lateral loads or forces in accordance with Sections 1609 and 1613 of the *International Building Code*. For purposes of this exception, comparisons of demand-capacity ratios and calculation of design lateral loads, forces and capacities shall account for the cumulative effects of *additions* and *alterations* since original construction.
- 2. Buildings of Group R occupancy with not more than five dwelling or sleeping units used solely for residential purposes where the *existing building* and the addition together comply with the conventional

light-frame construction methods of the *International Building Code* or the provisions of the *International Residential Code*.

**502.8** Additions to Group E facilities. For *additions* to Group E occupancies, storm shelters shall be provided in accordance with Section 1106.1.

#### **SECTION 503 ALTERATIONS**

**503.1 General.** Except as provided by Section 302.4, 302.5 or this section, *alterations* to any building or structure shall comply with the requirements of the *International Building Code* for new construction. *Alterations* shall be such that the *existing building* or structure is not less complying with the provisions of the *International Building Code* than the *existing building* or structure was prior to the *alteration*.

**[BS] 503.4 Existing structural elements carrying lateral load.** Except as permitted by Section 503.13, where the *alteration* increases design lateral loads, results in a prohibited structural irregularity as defined in ASCE 7, or decreases the capacity of any existing lateral load-carrying structural element, the structure of the altered building or structure shall meet the requirements of Sections 1609 and 1613 of the *International Building Code*. Reduced seismic forces shall be permitted.

**Exception:** Any existing lateral load-carrying structural element whose demand-capacity ratio with the *alteration* considered is not more than 10 percent greater than its demand-capacity ratio with the *alteration* ignored shall be permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the demand shall consider applicable load combinations with design lateral loads or forces in accordance with Sections 1609 and 1613 of the *International Building Code*. Reduced seismic forces shall be permitted. For purposes of this exception, comparisons of demand-capacity ratios and calculation of design lateral loads, forces and capacities shall account for the cumulative effects of *additions* and *alterations* since original construction.

**[BS] 503.11 Substantial structural alteration.** Where the *work area* exceeds 50 percent of the building area and where work involves a *substantial structural alteration*, the lateral load-resisting system of the altered building shall satisfy the requirements of Sections 1609 and 1613 of the *International Building Code*. Reduced seismic forces shall be permitted.

## **Exceptions:**

- 1. Buildings of Group R occupancy with not more than five dwelling or sleeping units used solely for residential purposes that are altered based on the conventional light-frame construction methods of the International Building Code or in compliance with the provisions of the International Residential Code.
- 2. Where the intended alteration involves only the lowest story of a building, only the lateral load-resisting components in and below that story need comply with this section.

503.12 Roof diaphragms resisting wind loads in high-wind regions. Where the intended alteration requires a permit for reroofing and involves removal of roofing materials from more than 50 percent of the roof diaphragm of a building or section of a building located where the ultimate design wind speed is greater than 115 mph (51 m/s) in accordance with Figure 1609.3(1) of the International Building Code or in a special wind region as defined in Section 1609 of the International Building Code, roof diaphragms, connections of the roof diaphragm to roof framing members, and roof-to-wall connections shall be evaluated for the wind loads specified in Section1609 of the International Building Code, including wind uplift. If the diaphragms and connections in their current condition are not capable of resisting 75 percent of those wind loads, they shall be replaced or strengthened in accordance with the loads specified in Section 1609 of the International Building Code.

**[BS] 503.13 Voluntary lateral force-resisting system alterations**. Structural *alterations* that are intended exclusively to improve the lateral force-resisting system and are not required by other sections of this code shall not be required to meet the requirements of Section 1609 or Section 1613 of the *International Building Code*, provided that all of the following apply:

- 1. The capacity of existing structural systems to resist forces is not reduced.
- 2. New structural elements are detailed and connected to existing or new structural elements as required by the International Building Code for new construction.
- 3. New or relocated nonstructural elements are detailed and connected to existing or new structural elements as required by the International Building Code for new construction.
- 4. The alterations do not create a structural irregularity as defined in ASCE 7 or make an existing structural irregularity more severe.

#### **SECTION 506 CHANGE IN OCCUPANCY**

**506.4 Structural.** Any building undergoing a *change of occupancy* shall satisfy the requirements of this section.

**506.4.2** Snow and wind loads. Where a change of occupancy results in a structure being assigned to a higher risk category, the structure shall satisfy the requirements of Sections 1608 and 1609 of the International Building Code for the new risk category.

**Exception:** Where the area of the new occupancy is less than 10 percent of the building area, compliance with this section is not required. The cumulative effect of occupancy changes over time shall be considered.

**506.4.4** Access to Risk Category IV. Any structure that provides operational access to an adjacent structure assigned to *Risk Category* IV as the result of a *change of occupancy* shall itself satisfy the requirements of Sections 1608, 1609 and 1613 of the *International Building Code*. For compliance with Section 1613, *International Building Code*-level seismic forces shall be used. Where operational access to the *Risk Category* IV structure is less than 10 feet (3048 mm) from either an interior lot line or from another structure, access protection from potential falling debris shall be provided.

#### **SECTION 507 HISTORIC BUILDINGS**

[BS] 507.4 Structural. Historic buildings shall comply with the applicable structural provisions in this chapter.

## **Exceptions:**

- 1. The *code official* shall be authorized to accept existing floors and existing live loads and to approve operational controls that limit the live load on any floor.
- 2. Repair of *substantial structural damage* is not required to comply with Sections 405.2.3, and 405.2.4. *Substantial structural damage* shall be repaired in accordance with Section 405.2.1.

User Note: For historic buildings damaged elements are allowed to be restored to their pre-damage condition.

#### **CHAPTER 7 ALTERATIONS – LEVEL 1**

#### SECTION 701 GENERAL

**701.1 Scope.** Level 1 alterations as described in Section 602 shall comply with the requirements of this chapter. Level 1 alterations to historic buildings shall comply with this chapter, except as modified in Chapter 12.

**701.2 Conformance.** An existing building or portion thereof shall not be altered such that the building becomes less safe than its existing condition.

**Exception:** Where the current level of safety or sanitation is proposed to be reduced, the portion altered shall conform to the requirements of the International Building Code.

## **SECTION 705 REROOFING**

[BS] 705.1 General. Materials and methods of application used for recovering or replacing an existing roof covering shall comply with the requirements of Chapter 15 of the *International Building Code*. [partial shown – exceptions omitted]

**[BS] 705.3 Roof replacement.** *Roof replacement* shall include the removal of all existing layers of roof coverings down to the roof deck.

**Exception:** Where the existing roof assembly includes an ice barrier membrane that is adhered to the roof deck, the existing ice barrier membrane shall be permitted to remain in place and covered with an additional layer of ice barrier membrane in accordance with Section 1507 of the *International Building Code*.

**[BS] 705.3.1 Roof recover.** The installation of a new roof covering over an existing roof covering shall be permitted where any of the following conditions occur:

- 1. The new roof covering is installed in accordance with the roof covering manufacturer's approved instructions.
- 2. Complete and separate roofing systems, such as standing-seam metal roof panel systems, that are designed to transmit the roof loads directly to the building's structural system and that do not rely on existing roofs and roof coverings for support, are installed.
- 3. Metal panel, metal shingle and concrete and clay tile roof coverings are installed over existing wood shake roofs in accordance with Section 705.4.
- 4. A new protective roof coating is applied over an existing protective roof coating, a metal roof panel, metal roof shingles, mineral-surfaced roll roofing, a built-up roof, modified bitumen roofing, thermoset and thermoplastic single-ply roofing or a spray polyurethane foam roofing system.

[BS] 705.3.1.1 Exceptions. A roof recover shall not be permitted where any of the following conditions occur:

- 1. The existing roof or roof covering is water soaked or has deteriorated to the point that the existing roof or roof covering is not adequate as a base for additional roofing.
- 2. The existing roof covering is slate, clay, cement or asbestos-cement tile.
- 3. The existing roof has two or more applications of any type of roof covering.

#### **SECTION 706 STRUCTURAL**

[BS] 706.3.2 Roof diaphragms resisting wind loads in high-wind regions. Where roofing materials are removed from more than 50 percent of the roof diaphragm or section of a building located where the ultimate design wind speed,  $V_{ult}$ , determined in accordance with Figure 1609.3(1) of the *International Building Code*, is greater than 115 mph (51 m/s) or in a special wind region, as defined in Section 1609 of the *International Building Code*, roof diaphragms, connections of the roof diaphragm to roof framing members, and roof-to-wall connections shall be evaluated for the wind loads specified in the *International Building Code*, including wind uplift. If the diaphragms and connections in their current condition are not capable of resisting at least 75 percent of those wind loads, they shall be replaced or strengthened in accordance with the loads specified in the *International Building Code*.

#### **CHAPTER 8 ALTERATIONS - LEVEL 2**

#### SECTION 801 GENERAL

**801.1 Scope.** Level 2 alterations as described in Section 603 shall comply with the requirements of this chapter.

**Exception:** Buildings in which the reconfiguration is exclusively the result of compliance with the accessibility requirements of Section 305.7 shall be permitted to comply with Chapter 7.

**801.2 Alteration Level 1 compliance.** In addition to the requirements of this chapter, all work shall comply with the requirements of Chapter 7.

**801.3** Compliance. All new construction elements, components, systems, and spaces shall comply with the requirements of the International Building Code.

**Exceptions:** [partial shown]

6. New structural members and connections shall be permitted to comply with alternative design criteria in accordance with Section 302.

#### **SECTION 806 STRUCTURAL**

**[BS] 807.1 General.** Structural elements and systems within buildings undergoing Level 2 alterations shall comply with this section.

**[BS] 806.3 Existing structural elements resisting lateral loads.** Except as permitted by Section 806.4, where the alteration increases design lateral loads, or where the alteration results in prohibited structural irregularity as defined in ASCE 7, or where the alteration decreases the capacity of any existing lateral load-carrying structural element, the structure of the altered building or structure shall be shown to meet the requirements of Sections 1609 and 1613 of the International Building Code. *[partial shown]* 

**Exception:** Any existing lateral load-carrying structural element whose demand-capacity ratio with the alteration considered is not more than 10 percent greater than its demand-capacity ratio with the alteration ignored shall be permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the demand shall consider applicable load combinations with design lateral loads or forces in accordance with International Building Code Sections 1609 and 1613. *[partial shown]* For purposes of this exception, comparisons of demand-capacity ratios and calculation of design lateral loads, forces and capacities shall account for the cumulative effects of additions and alterations since original construction.

**[BS] 806.4 Voluntary lateral force-resisting system alterations.** Structural alterations that are intended exclusively to improve the lateral force-resisting system and are not required by other sections of this code shall not be required to meet the requirements of Section 1609 or Section 1613 of the International Building Code, provided that the following conditions are met:

- 1. The capacity of existing structural elements required to resist forces is not reduced.
- 2. New structural elements are detailed and connected to existing or new structural elements as required by the International Building Code for new construction;
- 3. New or relocated nonstructural elements are detailed and connected to existing or new structural elements as required by the International Building Code for new construction.
- 4. The alterations do not create a structural irregularity as defined in ASCE 7 or make an existing structural irregularity more severe.

#### **CHAPTER 9 ALTERATIONS – LEVEL 3**

#### **SECTION 901 GENERAL**

**901.1 Scope.** Level 3 alterations as described in Section 604 shall comply with the requirements of this chapter.

**901.2 Compliance.** In addition to the provisions of this chapter, work shall comply with all of the requirements of Chapters 7 and 8. *[partial shown]* 

#### **SECTION 906 STRUCTURAL**

**[BS] 906.1 General.** Where buildings are undergoing Level 3 alterations including structural alterations, the provisions of this section shall apply.

**[BS] 906.2 Existing structural elements resisting lateral loads.** Where work involves a substantial structural alteration, the lateral load-resisting system of the altered building shall be shown to satisfy the requirements of Sections 1609 and 1613 of the International Building Code. Reduced seismic forces shall be permitted.

## **Exceptions:**

- 1. Buildings of Group R occupancy with not more than five dwelling or sleeping units used solely for residential purposes that are altered based on the conventional light-frame construction methods of the *International Building Code* or in compliance with the provisions of the *International Residential Code*.
- 2. Where the intended *alteration* involves only the lowest story of a building, only the lateral load-resisting components in and below that story need comply with this section.

## **CHAPTER 10 CHANGE OF OCCUPANCY**

#### **SECTION 1001 GENERAL**

**1001.1 Scope.** The provisions of this chapter shall apply where a *change of occupancy* occurs, as defined in Section 202.

#### **SECTION 1006 STRUCTURAL**

**[BS] 1006.2 Snow and wind loads.** Where a change of occupancy results in a structure being assigned to a higher risk category, the structure shall satisfy the requirements of Sections 1608 and 1609 of the International Building Code for the new risk category.

**Exception:** Where the area of the new occupancy is less than 10 percent of the building area. The cumulative effect of occupancy changes over time shall be considered.

#### **CHAPTER 11 ADDITIONS**

#### SECTION 1101 GENERAL

**1101.1 Scope.** An *addition* to a building or structure shall comply with the *International Codes* as adopted for new construction without requiring the *existing building* or structure to comply with any requirements of those codes or of these provisions, except as required by this chapter. Where an *addition* impacts the *existing building* or structure, that portion shall comply with this code.

**1101.2** Creation or extension of nonconformity. An *addition* shall not create or extend any nonconformity in the *existing building* to which the *addition* is being made with regard to accessibility, structural strength, fire safety, means of egress, or the capacity of mechanical, plumbing, or electrical systems.

#### **SECTION 1103 STRUCTURAL**

[BS] 1103.2 Lateral force-resisting system. Where the addition is structurally independent of the existing structure, existing lateral load-carrying structural elements shall be permitted to remain unaltered. Where the addition is not structurally independent of the existing structure, the existing structure and its addition acting together as a single structure shall meet the requirements of Sections 1609 and 1613 of the International Building Code using full seismic forces.

## **Exceptions:**

- 1. Buildings of Group R occupancy with no more than five dwelling or sleeping units used solely for residential purposes where the existing building and the addition comply with the conventional light-frame construction methods of the International Building Code or the provisions of the International Residential Code.
- 2. Any existing lateral load-carrying structural element whose demand-capacity ratio with the addition considered is not more than 10 percent greater than its demand-capacity ratio with the addition ignored shall be permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the demand shall consider applicable load combinations with design lateral loads or forces in accordance with Sections 1609 and 1613 of the International Building Code. For purposes of this exception, comparisons of demand-capacity ratios and calculation of design lateral loads, forces and capacities shall account for the cumulative effects of additions and alterations since original construction.

#### **SECTION 1106 STORM SHELTERS**

**1106.1** Addition to a Group E occupancy. Where an *addition* is added to an existing Group E occupancy located in an area where the shelter design wind speed for tornados is 250 mph in accordance with Figure 304.2(1) of ICC

500 and the occupant load in the *addition* is 50 or more, the *addition* shall have a storm shelter constructed in accordance with ICC 500.

## **Exceptions:**

- 1. Group E day care facilities.
- 2. Group E occupancies accessory to places of religious worship.
- 3. Additions meeting the requirements for shelter design in ICC 500.
- **1106.1.2 Location.** Storm shelters shall be located within the buildings they serve, or shall be located where the maximum distance of travel from not fewer than one exterior door of each building to a door of the shelter serving that building does not exceed 1,000 feet (305 m).

## **CHAPTER 13 PERFORMANCE COMPLIANCE METHODS**

#### **SECTION 1301 GENERAL**

- **1301.1 Scope.** The provisions of this chapter shall apply to the *alteration*, *addition* and *change of occupancy* of *existing structures*, including historic structures, as referenced in Section 301.3.3. The provisions of this chapter are intended to maintain or increase the current degree of public safety, health and general welfare in *existing buildings* while permitting, *alteration*, *addition* and *change of occupancy* without requiring full compliance with Chapters 6 through 12, except where compliance with other provisions of this code is specifically required in this chapter.
- **1301.2.3 Additions.** Additions to existing buildings shall comply with the requirements of the International Building Code or the International Residential Code for new construction. [partial shown]
  - **1301.2.3.1 Additions to Group E facilities.** For additions to Group E occupancies, storm shelters shall be provided in accordance with Section 1106.1.
  - **1301.3** Acceptance. For *repairs, alterations, additions*, and *changes of occupancy* to *existing buildings* that are evaluated in accordance with this section, compliance with this section shall be accepted by the *code official*.
  - **1301.4 Investigation and evaluation.** For proposed work covered by this chapter, the building owner shall cause the *existing building* to be investigated and evaluated in accordance with the provisions of Sections 1301.4 through 1301.9.
  - **[BS] 1301.4.1 Structural analysis.** The owner shall have a structural analysis of the *existing building* made to determine adequacy of structural systems for the proposed *alteration*, *addition* or *change of occupancy*. The analysis shall demonstrate that the building with the work completed is capable of resisting the loads specified in Chapter 16 of the *International Building Code*.
- **1301.4.3 Determination of compliance.** The *code official* shall determine whether the *existing building*, with the proposed *addition*, *alteration*, or *change of occupancy*, complies with the provisions of this section in accordance with the evaluation process in Sections 1301.5 through 1301.9.

## **CHAPTER 14 RELOCATED OR MOVED BUILDINGS**

### **SECTION 1402 REQUIREMENTS**

**[BS] 1402.3 Wind loads.** Buildings shall comply with International Building Code or International Residential Code wind provisions as applicable.

## **Exceptions:**

- 1. Detached one- and two-family dwellings and Group U occupancies where wind loads at the new location are not higher than those at the previous location.
- 2. Structural elements whose stress is not increased by more than 10 percent.

# APPENDIX C: GUIDELINES FOR THE WIND RETROFIT OF EXISTING BUILDINGS CHAPTER C1 GABLE END RETROFIT FOR HIGH-WIND AREAS

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

#### SECTION C101 GENERAL

[BS] C101.1 Purpose. This chapter provides prescriptive methods for partial structural retrofit of an existing building to increase its resistance to out-of-plane wind loads. It is intended for voluntary use and for reference by mitigation programs. The provisions of this chapter do not necessarily satisfy requirements for new construction. Unless specifically cited, the provisions of this chapter do not necessarily satisfy requirements for structural improvements triggered by addition, alteration, repair, change of occupancy, building relocation or other circumstances. [partial shown]

## CHAPTER C2 ROOF DECK FASTENING FOR HIGH-WIND AREAS

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

#### **SECTION C201 GENERAL**

[BS] C201.1 Purpose. This chapter provides prescriptive methods for partial structural retrofit of an existing building to increase its resistance to wind loads. It is intended for voluntary use where the ultimate design wind speed, V<sub>ult</sub>, determined in accordance with Figure 1609.3(1) of the International Building Code exceeds 130 mph (58 m/s) and for reference by mitigation programs. The provisions of this chapter do not necessarily satisfy requirements for new construction. Unless specifically cited, the provisions of this chapter do not necessarily satisfy requirements for structural improvements triggered by addition, alteration, repair, change of occupancy, building relocation or other circumstances.

**[BS] C201.2 Eligible conditions.** The provisions of this chapter are applicable only to buildings that meet the following eligibility requirements:

- 1. Buildings assigned to Risk Category I or II in accordance with International Building Code Table 1604.5; or
- 2. Buildings within the scope of the International Residential Code.

\* \* \* \* \* \* \*