

# Emergency Management Insights from Dam Failures & Incidents

National Dam Safety Program Technical Seminar | 2024

Mark Baker, P.E.  
Senior Dam Safety Program Engineer



# Plan for talk

- Definitions
- Case Studies with Insights (Lessons)
- Wrap up

# **Dam Failure Definition:**

**Catastrophic type of failure characterized by the sudden, rapid, and uncontrolled release of impounded water**

# Dam Incident Definition:

**Dam Safety Incident:** An incident where a failure mode initiates and progresses but does not progress to an uncontrolled release of the reservoir.

**Operational Incident:** Controlled release that results in property damage or loss of life.

**Public Safety Incident:** When an individual is seriously injured, killed or required rescue, due to presence or operations of a dam.

**Security Incident:** Not addressed.



# Oroville Dam 2017



**Pop Quiz: Failure  
or Incident 1**



**FEMA**



**Pop Quiz: Failure  
or Incident 2**

**Lake Delhi Dam, 2010**

## More on Incidents

**Dam Safety Incident:** An event where a failure mode initiates and progresses but does not progress to an uncontrolled release of the reservoir.

- More incidents happen than failures
- Can be minor or major
- May or may not be detected
- May lead to failure or may resolve on own or be stopped by intervention
- All failures start out as incidents

Examples: Slides, seeps, cracks, sinkholes, flood event



**FEMA**



## More on Incidents and Failures

**Dam Safety Incident:** An incident that results in a failure mode that was not progressive and the reservoir.

### Insights:

- Incidents are often a surprise (random)
- but are more likely during:
  - Floods/earthquakes
  - High reservoir levels
  - Major spillway flows
  - First time the reservoir fills after construction or major modification

Examples: Slides, seeps, cracks, sinkholes, flood event



FEMA



**The Worst Case** – Undetected incident that progresses to failure – No intervention, warning and Evacuation

No EAP



- A jungle/mountain Dam
- Dam failed before dawn from sliding, overtopping
- After heavy rain
- No detection, warning or evacuation
- 7 people killed including a pregnant woman



FEMA

Kaloko Hawaii, 2006



# The Worst Case – Undetected incident that progresses to failure – No Warning and Evacuation

No EAP



**Insights:**

- It is more challenging to operate, maintain, and monitor remote dams.
- Incidents and failures at these dams may go unnoticed until it is too late.

maintain Dam  
fore dawn  
ertopping

- no detection, warning or evacuation
- 7 people killed including a pregnant woman

Kaloko Hawaii, 2006



FEMA

## The Worst Case – Undetected incident that progresses to failure – No Warning and Evacuation

- Failed suddenly around midnight
- New 205-ft-high dam
- Failed on first filling
- High velocity/deep flood
- ~450 lives lost
- Motorcyclist raced downstream warning

No EAP



FEMA



**St. Francis Dam, CA 1928**



## The Worst Case – Undetected incident that progresses to failure – No Warning and Evacuation

- Failed suddenly and without warning
- New 20th century dam
- Failed on first filling
- High velocity flow
- ~450 lives lost
- Motorcyclist

### Insights:

- New dams and dams that have had major repairs should be carefully monitored for first filling
- Have an EAP and exercise before first filling



FEMA

St. Francis Dam, CA 1928



## The Worst Case – Undetected incident that progresses to failure – No Warning and Evacuation

No EAP



**Libya Dam Failures 2023**

- 2 dams failed at night after Mediterranean storm Daniel
- City of Derna downstream
- 3:00AM
- 25% of the city “disappeared”
- No warning/Evacuation
- 5,300 -20,000 killed

## The Worst Case – Undetected incident that progresses to failure – No Warning and Evacuation

No EAP

**Insights:**

- Dams above major populated areas should: receive extra care (O&M)
- Be well monitored (especially during floods)
- Have EAPs and exercises

Unless zoned, people will move right up to the channel

- 2 dams failed at night after Mediterranean storm Daniel
- City of Derna downstream
- 3:00AM
- 25% of the city “disappeared”
- No warning/Evacuation
- 5,300 -20,000 killed

## Libya Dam Failures 2023



## The Best Case – No incidents or failure.

- Dam designed and built well
- Properly maintained and operated.



*Jordannelle Dam / Reservoir  
(Provo River)  
north of Heber City  
Wasatch County / Utah  
31.05.2008 11:03*



**FEMA**

## The Best Case – No incidents or failure.

- Dam designed and built well
- Properly maintained and operated.

### Insights:

- No dam is risk free
- Dams that appear fine may have masked vulnerabilities
- Protection of public safety requires dams with people downstream to have EAPs



FEMA

Jordannelle Dam / Reservoir  
(Provo River)  
north of Heber City  
Wasatch County / Utah  
31.05.2008 11:03

## The Reality Case - Incidents

**may happen** and if you are prepared, you can make a difference

Step 1: Make sure you detect incidents **Detection** is the discovery of an initiating event at a dam, examples:

- High water,
- Increased seepage
- Cloudy seepage,
- Concrete movement
- Slides, slumps, cracks





## The Reality Case – Incidents may happen and if you are prepared, you can make a difference

### Step 1: Detect by:


- Keeping vegetation down
- Make all parts of the dam accessible
- Training staff at dams what to look for
- Make them comfortable to report
- Eyes on dam frequently
- Earlier discovery the better



**The Reality Case** – Incidents may happen and if you are prepared, you can make a difference

**Step 2: Notify**

- Follow EAP
- Assess severity with help of engineers
- Notify



If severity is deemed **Minor**:

- Some call “Internal Alert”
- Continue to monitor
- Communicate regularly
- Prepare for if it gets worse



If severity is deemed **Major**

- Declare EAP response level 1 or greater
- Consider Intervention.



**Intervention** – Taking actions to slow or stop a failure mode (incident) in progress.

- Can be successful: dam does not fail
- Can be unsuccessful: dam fails
- Intervention (even unsuccessful intervention) can delay failure to allow more time for warning and evacuation)



# Successful Intervention Example




**FEMA**

**Guajataca Dam, PR – Pre-Incident**



# Successful Intervention Example

Hurricane Irma,  
Guajataca Dam,  
PR Sep 2017




FEMA



## Successful Intervention Example


The National Weather Service warned Friday that the failure of Guajataca Dam in northwest Puerto Rico was "imminent" and could lead to flash flooding for some 70,000 people that could be affected if it collapsed.



**FEMA**

**Guajataca Dam, PR Sep 2017**

**Successful  
Intervention  
Example**




**US Army Corps  
of Engineers®**



**Guajataca Dam, PR Sep 2017**



# Successful Intervention Example



**US Army Corps  
of Engineers®**

**Guajataca Dam, PR Sep 2017**




Insights:

Get help:

- Dam engineering expertise
- Equipment, materials, operators
- Plan for assistance in EAP

**Successful  
Intervention  
Example**



**US Army Corps  
of Engineers®**



**Guajataca Dam, PR Sep 2017**



# Another Success Intervention Example



**Fontenelle Dam, WY 1965**

1 mile long, 126 ft high, 345,000 ac-ft  
New dam, first filling in 1965

# Day 1

Friday Sept 3, 1965



## Fontenelle Dam, WY 1965





Photo changed  
from original to  
show progression

10:30 AM small trickle of water  
on downstream face of the  
dam



Photo changed from original to show progression



# Day 1

Friday Sept 3, 1965



**Insights:**  
Monitor dams. Frequently monitor dams in first filling status

10:30 AM small trickle of water on downstream face of the dam

## Fontenelle Dam, WY 1965

# Day 1

Friday Sept 3, 1965



- Had his other staff monitor the seepage/leak

**Fontenelle Dam, WY 1965**

- Had his other staff monitor the seepage/leak



# Day 1

Friday Sept 3, 1965



**Insights:**  
Boost monitoring of problem areas  
During dam incidents – especially long duration incidents - are highly demanding of staff time. Call people into help and relieve local staff



# Day 1

Friday Sept 3, 1965



Photo changed  
from original to  
show progression

**Fontenelle Dam, WY 1965**

4:00 PM 1 cubic-ft/sec (440 gal/min) leak

# Day 1

Friday Sept 3, 1965



**Fontenelle Dam, WY 1965**

6:00 PM 5 cubic-ft/sec (2200 gal/min leak)

# Day 1

Friday Sept 3, 1965



Photo changed from original to show progression

**Insight:**  
The situation can change rapidly and accelerate.

**Fontenelle Dam, WY 1965**

6:00 PM 5 cubic-ft/sec (2200 gal/min leak



# Day 1

Friday Sept 3, 1965



- Called Denver Engineering center and the Salt Lake City Regional Office

**Fontenelle Dam, WY 1965**

6:00 PM 5 cubic-ft/sec (2200 gal/min leak

# Intervention Example

Day 1

Friday Sept 3, 1965



- Called Denver Engineering center and the Salt Lake City Regional Office

**Insight:**


- EAPs should contain contacts for quickly getting technical expertise
- Don't go it alone in the field.

**Fontenelle Dam, WY 1965**

6:00 PM 5 cubic-ft/sec (2200 gal/min) leak

# Day 1

Friday Sept 3, 1965




**Fontenelle Dam, WY 1965**

7:30 PM 10 cubic-ft/sec (4400 gal/min) leak



# Day 1

Friday Sept 3, 1965



- Called the county sheriffs
- Told them the dam might fail
- Urged evacuation of areas downstream of the dam and put the town of Green River on alert
- Continuous watch
- No EAP, but these are dam owner responsibilities typically in an EAP

**Fontenelle Dam, WY 1965**

7:30 PM 10 cubic-ft/sec (4400 gal/min/min leak

# Day 1

Friday Sept 3, 1965



- Called the county sheriffs
- Told them the dam might fail
- ...ation

## Insights:

- Consistent with ICS, the senior person on site is in charge until relieved.
- Tough calls need to be made based on incomplete information and changing conditions.

**Fontenelle Dam, WY 1965** 1:00 PM 10 cubic-ft/sec (4400 gal/min) leak





## Town of Green River





**FEMA**



# Day 2

Friday Sept 4, 1965



Chief Engineer  
Barney Bellport  
And his engineers


## Fontenelle Dam, WY 1965

I D A H O

W Y O M I N G

○ Burley

FONTENELLE DAM



Ogden



Green River

○ Rock Springs

CHEYENNE ○

● SALT LAKE CITY

Regional Director  
David Crandall



I D A H O

W Y O M I N G

○ Burley

FONTENELLE DAM

### Insights:

- Information during incidents is sketchy, incomplete, and changes.
- “Over respond” (get to the site) to make sure you are in a good position to respond if it gets serious

REYENNE ○



○ DE

L O R A D

Grand Junction

ADO





# Intervention Example

**Day 2**

Sat Sept 4, 1965

Cavity 170 ft-long,  
65-ft wide, 50-ft  
deep



**Fontenelle Dam, WY 1965**

# Intervention Example

Day 2

Sat, Sept 4, 1965




**Fontenelle Dam, WY 1965**



# Intervention Example

Day 2

Friday Sept 3, 1965



**Fontenelle Dam, WY 1965**




# Intervention Example

Day 2

Friday Sept 3, 1965

*Insights:*

- Consider inviting public safety officials to come see a developing incident themselves



**Fontenelle Dam, WY 1965**

# Intervention Example

Day 2

Friday Sept 3, 1965



**Fontenelle Dam, WY 1965**



# Intervention Example

Day 2

Friday Sept 3,

Insight:

- Get the best technical, local and regional people together to evaluate the situation, come up with options and decide what to do.



**Fontenelle Dam, WY 1965**



# Intervention Example

Day 2

Sat Sep 4, 1965




Decision: Lower the Reservoir

**Fontenelle Dam, WY 1965**

# Intervention Example

Day 2

Sat Sep 4, 1965



**Fontenelle Dam, WY 1965**

Decision: fill the void to stop the cavity from getting bigger

# End of Day 2

Sat Sep 4, 1965

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
BUREAU OF RECLAMATION

Regional Office - Region 4  
Salt Lake City, Utah

September 4, 1965

P R E S S   R E L E A S E

The small leak which developed Friday night near the right abutment of Fontenelle Dam is serious but not critical, B. P. Bellport, Chief Engineer for the Bureau of Reclamation said today. Immediate steps are being taken to eliminate all danger by lowering the Fontenelle Reservoir level and by filling the eroded area



**FEMA**



# End of Day 2

Sat Sep 4, 1965

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
BUREAU OF RECLAMATION

Regional Office - Region 4  
Salt Lake City, Utah

September 4, 1965

## P R E S S   R E L E A S E

The small leak which developed Friday night near the right abutment of Fontenelle Dam is serious but not critical, B. P. Bellport, Chief Engineer for the Bureau of Reclamation said today. Immediate steps are being taken to eliminate all danger by lowering the Fontenelle Reservoir level and by filling the eroded area

- Insights:
- For a major incident, get ahead of rumors – push out quality info with press releases – get your public affairs people involved.




# FEMA

# Intervention Example

**Day 3**

Sunday Sept 5,  
1965




**Fontenelle Dam, WY 1965**

# Intervention Example

## Day 3

Sunday Sept 5,  
1965



### Insights:

- Borrow or rent needed equipment


**Fontenelle Dam, WY 1965**



# Intervention Example

Day 3

Sunday Sept 5,  
1965



**“Encouraging”**

**Fontenelle Dam, WY 1965**

# Intervention Example

Day 3

Sunday Sept 5  
1965

*Insights:*

- Don't get cocky/overconfident
- The situation can change rapidly during an incident...
- As we will see . . . .



**“Encouraging”**

**Fontenelle Dam, WY 1965**




# Intervention Example

Day 3

Sunday Sept 5,  
1965

**Fontenelle Dam, WY 1965**





# Day 4

Monday Sept 5,  
1965



## Fontenelle Dam, WY 1965

# Day 4

Monday Sept 5,  
1965



## Fontenelle Dam, WY 1965

# Day 4

Monday Sept 5,  
1965



## Fontenelle Dam, WY 1965



# Day 4

Monday Sept 5,  
1965

- 15 x 20-ft sinkhole appeared with a woosh and a cloud of dust
- One person raced down to the town of Green River and told people the dam was failing.
- The Sheriff said “I have Reclamation on the phone and the water is still in the reservoir”.



## Fontenelle Dam, WY 1965

# Day 4

Monday Sept 5,  
1965

- 15 x 20-ft sinkhole appeared with a wo... and a cloud of dust
- One person raced to the town of Gree... River and told people the dam was failing
- The Sheriff said "I have Reclamation on the phone and the water is still in the reservoir".

## Insights:


- Remain in close communication with public safety officials during an incident.



## Fontenelle Dam, WY 1965

Day 4

Monday Sep  
1965




**Fontenelle Dam, WY 1965**



**Day 4**

Monday Sep  
1965



**Fontenelle Dam, WY 1965**

# Day 4

Monday Sept 5,  
1965



**Decided to immediately fill void**

**Fontenelle Dam, WY 1965**

## Day 4

Monday Sept 5,  
1965



- Insights:**
- In acute, high-pressure situations, empower your people to do what needs to be done – confirm with officials and technical staff ASAP.

**Decided to immediately fill void**

**Fontenelle Dam, WY 1965**



**Day 7**

Thurs Sep 7, 1965



**Governor visited, lots of press**

**Fontenelle Dam, WY 1965**

# Day 7

Thurs Sep 7, 1965

## Insights:

- Major incidents attract a lot of press, public and governmental attention



**Governor visited, lots of press**



**FEMA**



# Intervention Example

Day 8

Fri Sept 10, 1965



**Fontenelle Dam, WY 1965**



## Day 10

Sunday Sep 12,  
1965

BUREAU OF RECLAMATION  
Fontenelle, Wyoming  
SUNDAY, Sunday, September 12, 1965

"The alert called on Friday, September 3, when  
developed a serious leak was lifted at 9:00 AM today.  
David L. Crandall announced at Fontenelle, Wyoming.  
of Reclamation crews under Project Construction End

## Fontenelle Dam, WY 1965

# Day 10

Sunday Sep 12,  
1965

NOTES BY D. L. CRANDALL,  
REGIONAL DIRECTOR, REGION 4

Friday, September 3  
10:30 a.m.

Hatch, with

to 25 feet

at about ele-

slough area

1/2 feet in depth.

**Insights:**  
• Officially declare your emergency ended.

Dick

Hatch, with Inspector/Horsburgh, attempted to divert the flow away from the location where it was overflowing into the spillway stilling

at this time we estimated

## Fontenelle Dam, WY 1965

NOTES BY D. L. CRANDALL,  
REGIONAL DIRECTOR, REGION 4

Friday, September 3  
10:30 a.m.

Hatch noticed small trickle of water flowing out 20 to 25 feet east of the spillway wall opposite spillway station 4+35 at about elevation (obtained from map). Small "V" notch slough area being developed from this trickle about 1 1/2 feet in depth.

4:00 p.m.

Dick  
Hatch, with Inspector/Horsburgh, attempted to divert the flow away from the location where it was overflowing into the spillway stilling



NOTES BY D. L. CRANDALL  
REGIONAL DIRECTOR

Friday, Sept  
1965

- Insights:
- Document the incident in proportion to its magnitude and potential lessons.
  - Hotwash as a group (exercise credit)

...burgh, attempted to divert the flow away  
...ion where it was overflowing into the spillway stilling

## Fontenelle Dam, WY 1965

# Another Successful Intervention Example

- Ring Dam
- Edge of the Great Salt Lake and I-15
- 14.5 miles long
- 36-ft-High
- 215,000 ac-ft



A.V. Watkins Dam 2006

**Day 1:  
November  
11, 2006**  
Feedlot  
operator  
noticed  
seepage into  
the South  
Drain



## **A.V. Watkins Dam 2006**



**Day 1:**  
**November**  
**11, 2006**  
Feedlot  
operator  
noticed  
seepage into  
the South  
Drain

- 
- Insights:**
- Sometimes dam problems are found by the public or those who live and work near dams

**A.V. Watkins Dam 2006**

**Day 2,  
November  
12, 2006**

Feedlot  
operator  
saw  
seepage  
continuing.  
No  
notification



**A.V. Watkins Dam 2006**

**Day 2,  
November  
12, 2006**

Feedlot  
operator  
saw  
seepage  
continuing.  
No  
notification



**Insights:**

- Train people who live, work and frequent your dams what early problems at dams look like and “see something, say something”

**A.V. Watkins Dam 2006**



## Day 3, November 12, 2006

- Feedlot operator saw seepage color change and notified district
- District visited dam and called Reclamation staff
- About 1:00PM Reclamation staff left for the dam



**A.V. Watkins Dam 2006 1**

**November 13, 2006**

- Reclamation responded - Declared EAP Response Level 1 but implemented some steps from Response Level 2

## A.V.WATKINS DAM & RESERVOIR



### **EMERGENCY ACTION PLAN**

Watkins UT

October 27, 2009

Bureau of Reclamation,  
US Department of the Interior



**FEMA**

November 13, 2006

- Stationed equipment on west dam (LOW hazard section)
- Opened outlet works - just 4 inches/day lowering

## A.V.WATKINS DAM & RESERVOIR



FEMA



November 13, 2006

- Ordered Filter/drain materials and equipment
- Rented Light plants
- While in transit to site
- **UNAUTHORIZED PURCHASES!!!!**



FEMA


## November 13, 2006

- Ordered Filter/drain materials and equipment
- Rented Light plants
- While in transit to site
- **UNAUTHORIZED PURCHASES!!!!**

# A.V. Watkins Dam 2006

### Insights:

- Plan for night work in an emergency
- Make sure the people who will be responding to dam incidents have the authority to make immediate purchases.





11/13/06

What they found arriving on site was alarming:  
Foundation Internal erosion was well-advanced

150 – 250 gpm of  
seepage exiting  
sand boils at toe of  
dam



A.V. Watkins Dam 2006



11/13/06


**Seven sand boils at the  
downstream (d/s) toe,  
Rapid piping of  
foundation materials**



**A.V. Watkins Dam 2006**



**Numerous sinkholes  
between the d/s toe and the  
south drain up to 6 to 7 feet  
deep**



**A.V. Watkins Dam 2006**



**Slope stability  
failure initiating with  
cracking extended to  
upstream crest**



**A.V. Watkins Dam 2006**



Filter placement  
11/13/06

**Started to place sand/gravel filter over boils**



**A.V. Watkins Dam 2006**



View looking u/s at filter/gravel "berm"  
11/14/06



A.V. Watkins Dam 2006





**A.V. Watkins Dam 2006**



3 Days Later,  
Nov 17, 2006



A.V. Watkins Dam 2006





3 Days Later,  
Nov 17, 2006

Insights:

- Continue regular monitoring even after you think the problem is resolved
- Don't end the incident until a period showing sufficient satisfactory performance has passed.





**A.V. Watkins Dam 2006**





**A.V. Watkins Dam 2006**





**A.V. Watkins Dam 2006**

# Insight: It was a Team Effort

## INTERNAL

- Area Office
- Regional Office
- Dam Safety Office
- TSC
- Washington

## EXTERNAL

- WBWCD (District)
- County Authorities
- Congressional
- Public/Land Owners
- State
- Press



## Source Credit

- Bruce Barrett, Bureau of Reclamation
  - Upper Colorado Regional Office

# Successful Intervention: 2006 Lake Needwood Dam Seepage Incident

- 65-ft-high Embankment Dam in Maryland
- Seep at left groin





# Lake Needwood Dam Seepage Incident 1



- In June, 2006 heavy rains caused a 23 foot rise in Lake Needwood, located in suburban Washington, D.C.
- Uncontrolled cloudy seepage through the dam and foundation occurred and the dam was on the verge of failure.

Lake Needwood Dam Seepage Incident

# Lake Needwood Dam Seepage Incident 2



Lake Needwood Dam Seepage Incident



# Lake Needwood Dam Seepage Incident 3



Insight:  
Ensure there is truck access to as many of the areas of the dam as possible - especially the downstream toe

# Lake Needwood Dam Seepage Incident 4

A human “bucket brigade” was used to transport sand and gravel to the seepage location



Lake Needwood Dam Seepage Incident



# Lake Needwood Dam Seepage Incident 5

A human “bucket brigade” was used to transport sand and gravel to the seepage location



## Insights:

- Improvise if necessary
- EAPs should include sources for sand, gravel, equipment rental and operators

# Lake Needwood Dam Seepage Incident 6

Filter fabric, sand, and gravel were used to control the seepage as the reservoir was drawn down.



Lake Needwood Dam Seepage Incident



# Lake Needwood Dam Seepage Incident, 2006

- After 2 nights, evacuees were allowed to return to their homes.

# Detection with Monitoring, Warning and Evacuation (no intervention) and Failure 1




## 2020 Edenville and Sanford Dam Failures



# Detection with Monitoring, Warning and Evacuation

## 2

- Edenville and Sanford dams were hydropower embankment dams on the same Tittabawasse River



### Edenville and Sanford Dam Failures

# Detection with Monitoring, Warning and Evacuation

## 3

- Late May 2020: 3” to 6” of rain on frozen ground and snowmelt event

1. Dams in Series can affect each other when passing storm flows or during dam failures. They act as a system.
2. EAPs should include upstream and downstream scenarios, communication and effects




# Detection with Monitoring, Warning and Evacuation

## 4


- Edenville and Sanford dams were hydropower embankment dams **nearly 100 years old**

### Edenville and Sanford Dam Failures



# Detection with Monitoring, Warning and Evacuation

## 5




- Edenville and Sanford dams were hydropower embankment dams nearly 100 years old

Insight:

1. Even dams with decades of successful operation can fail.

Edenville and Sanford Dam Failures



Sanford Dam




# Detection with Monitoring, Warning and Evacuation

## 6

- Late May 2020: 3" to 6" of rain on frozen ground and snowmelt event

### Edenville and Sanford Dam Failures



# Detection with Monitoring, Warning and Evacuation


## 7



- Late May 2020: 3” rain on frozen ground snowmelt event

1. Beware late spring rainstorms:  
Rain on snow and rain on frozen ground dramatically increases the amount of flood water.

Edenville and Sanford Dam Failures





# Detection with Monitoring, Warning and Evacuation



Edenville  
Dam

- Edenville and Sanford dams were hydropower embankment dams

Sanford Dam  
10 miles  
downstream




- Edenville and Sanford dams were hydropower embankment dams




## Sanford Dam

- Edenville embankment




1. Hydropower dams have many components: gates, spillways, powerhouses.
2. The dam can fail at any location
3. They often have to open gates to pass large floods

The City of Midland Mich, population 42,000 was about 8 miles from Sanford Dam.






On evening of May 18, the Midland County EM was in a quandary. Water was rising behind Edenville Dam. She was not comfortable with the reports she was receiving from the dam operator concerning conditions at the dam. The EAP stipulated that she was only to order evacuation if the failure was imminent, or the dam already failed.



## Edenville and Sanford Dam Failures



On evening of May 18, the Midland County EM was in a quandary. Water was rising behind Edenville Dam. She was not comfortable with the reports she was receiving from the dam operator concerning conditions at the dam. The EAP stipulated that she was only to order evacuation if the failure was imminent, or the dam already failed.



## Insights

1. Information during event is incomplete
2. Decisions need to be made
3. The dam operator/owner role and the Emergency Manager roles are different




# Detection with Monitoring, Warning and Evacuation

## 9

With 3,500 people in the path of the dam failure flood path, she weighed other factors:

- It would take six hours to evacuate everyone
- If Edenville Dam failed it would cut off many evacuation routes
- If she waited until the morning, the volunteer firefighters in Edenville and Jerome townships would be at work, unable to assist






# Detection with Monitoring, Warning and Evacuation 10

She ordered the evacuation.  
The evacuation was conducted  
during the night of May  
18/May 19.

Edenville dam failed the next  
afternoon.






# Detection with Monitoring, Warning and Evacuation Insights

She ordered the evacuation.  
The evacuation was conducted during the night of May 18/May 19.

Edenville dam failed the next afternoon.



The failure began with a drop in the crest of the dam.

Shown here at 5:31pm.

**Edenville and Sanford Dam Failures 1**





4 minutes  
later



**Edenville and  
Sanford Dam  
Failures 2**

4 minutes  
later  
Plus 6  
seconds



**Edenville and  
Sanford Dam  
Failures 3**



4 minutes  
later  
Plus 8  
seconds



**Edenville and  
Sanford Dam  
Failures 4**

4 minutes  
later

Plus 28  
seconds

Cause: static  
liquefaction

**Edenville and  
Sanford Dam  
Failures 5**





4 minutes  
later  
Plus 8  
seconds



**Edenville and  
Sanford Dam  
Failures 6**

4 minutes  
later  
Plus 8  
seconds

**Edenville and  
Sanford Dam  
Failures 7**





4 minutes  
later  
Plus 8  
seconds



**Edenville and  
Sanford Dam  
Failures 8**



4 minutes later  
Plus 28 seconds

**Edenville and Sanford Dam Failures 9**





Water from the failed Edenville Dam went downstream and overflowed Sanford Dam. About an hour and a half after Edenville Dam failed, Sanford Dam failed.

## Edenville and Sanford Dam Failures 11



\$200 million in damages, 2,500 buildings flooded, **no loss of life**, a Presidentially-declared disaster.





Jenifier Boyer, emergency management coordinator for Midland County. (Courtesy photo)

The emergency manager received an award from the Association of State Dam Safety Officials later that year for her actions during the event.



Mark Baker  
DamCrest Consulting  
[mark@damcrest.com](mailto:mark@damcrest.com)



FEMA